

ROCKY FLATS ENVIRONMENTAL TECHNOLOGY SITE

REGULATORY CONTACT RECORD

Date/Time: 03/11/04 - 1445

Site Contact(s): C. J. Freiboth (KH) – (CJF-073)
Phone: (303) 966-2823

Regulatory Contact: David Kruchek, CDPHE
Phone: (303) 692-3328

Agency: CDPHE

Purpose of Contact: Disposition of Embedded Unistrut, Electrical Conduit and Outlet Receptacles, and Junction Boxes, Building 444 Complex

Meeting Attendance: C. J. Freiboth, KH PM David Kruchek, CDPHE

Discussion

On March 11, 2004, at 1445, during a Building 444 Complex focus meeting, a discussion was held with the State (Kruchek) regarding the appropriate disposition of embedded unistrut, electrical conduit and outlet receptacles, and junction boxes in relation of final building disposition. Removal of these items during dismantlement activities or during facility demolition is not feasible. The State (Kruchek) concurred that these items could be dispositioned by performing the following: (1) decontaminating / wet wiping the embedded items, (2) taking removable radiological smears and beryllium smears, (3) if radiological smears were negative (meet PDS free release criteria) then spray them with an appropriate fixative such as fire-dam. Debris with embedded unistrut, electrical conduit and outlet receptacles, and junction boxes, will not be recycled on site, but will be properly characterized and disposed off-site.

Contact Record Prepared By: C. J. Freiboth

Required Distribution:	D. Kruchek, CDPHE
M. Aguilar, USEPA	J. Legare, RFFO
S. Bell, DOE	R. Leitner, KH
R. Birk, DOE	D. Maxwell, DOE
C. Deck, KH	J. Mead, KH
D. Foss, KH	S. Nesta, KH
C. Gilbreath, KH	K. North, KH
S. Gunderson, CDPHE	R. Schassburger, DOE
L. Kilpatrick, DOE	D. Shelton, KH
G. Kleeman, USEPA	C. Zahm, KH

Additional Distribution:

C. J. Freiboth, KH
J. Hindman, CDPHE
G. Morgan, DOE
D. Parsons, KH
K. Shuler, RFCSS

